



Product certificate K101430/01

Issued 2019-06-15

Replaces

Page 1 of 2

Repair Clamps

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Krausz Industries Ltd

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline

BRL-K777: "Repair Clamps", dated: 23-12-2016.

Ronald Karel
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

CERTIFICATE

286180711

Kiwa Nederland B.V.

Sir Winston Churchillaan 273
P.O.Box 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
info@kiwa.nl
www.kiwa.nl

Supplier

Saint-Gobain PAM Nederland BV
Markerkant 10-17
1316 AB ALMERE
The Netherlands
Tel. +31 36 548 76 20
pamnederland@saint-gobain.com
www.pamline.nl

Producer

Krausz Industries Ltd.
6 Hapatish Street
6655906 TEL AVIV
Israel
Tel. +972 3 5154000
info@krausz.com
www.krausz.com



Certification process
consists of initial and
regular assessment of:

- quality system
- product

Repair Clamps

PRODUCT SPECIFICATION

The products mentioned below belong to this technical approval-with-product certificate

Type of repair clamp	Diameter range of pipe (mm)
REPAMAX	15 up to and including 400

Fitness for contact with drinking water



This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

MARKING

The Kiwa®-mark products are marked with the word mark "KIWA  or the abbreviated word mark 

Place of the mark:

- on the clamp

Compulsory specifications:

- manufacturer's name or logo;
- data or code indicating the date of production;
- type indication;
- minimum and maximum pipe diameter (mm) for which the repair clamp can be used;
- nominal pressure.

Method of marking:

- non-erasable;
- visible after assembly.

APPLICATION AND USE

The products are intended to be used in piping systems with a maximum water pressure of 1,0 MPa, a water temperature of not more than 30°C and a nominal diameter greater than or equal to 15 mm and less than or equal to 400 mm. The products are intended to repair cracks, holes and fractures and to make permanent connections with the mentioned piping systems.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Saint-Gobain PAM Nederland B.V.

and, if necessary,

- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.